


- NOTES:
1. BASE THICKNESS AND REINFORCING VARIES WITH TRAFFIC, CLIMATE, AND SUBGRADE CONDITIONS.
 2. CONCRETE BASE MINIMUM 2% SLOPE FROM CENTERLINE TO CURB.
 3. DO NOT PROVIDE WEEP HOLES TO SUBGRADE WHEN WATER TABLE IS LESS THAN 2 FT. (0.6 M) FROM TOP OF SOIL SUBGRADE. PROVIDE DRAIN HOLES TO CATCH BASINS.



**CROSSWALK ON CONCRETE BASE
WITH BITUMEN SETTING BED**

DRAWING NO.	ICPI-71
SCALE	NO SCALE